




DRINKING WATER REPORT FOR LEAD AND COPPER

Date Collected:	See Below	System Group Type:	A
Water System ID #:	19948X	System Name:	Driftwood Heights Association
Source	S93 (Distribution Samples)	County:	Island
Sample Location:	See Below	Consecutive System:	Unknown
Sample Purpose:	RC - Routine/Compliance	Date Received:	08/05/15
Sample Composition:	D - Distribution Sample	Date Analyzed:	08/21/15
Supervisor:	 Mark Lorenz	Date Reported:	08/27/15
		Sampler Comments:	
		Sample Type:	Treated
		Sample Collected by:	F. Pedroza
		Phone Number:	(360) 678-5336
Send Report To:	King Water c/o Sandra Bodamer PO Box 2243 Oak Harbor, WA 98277	Bill To:	Same

	LEAD	COPPER
DOH #	0009	0023
SRL	0.001 mg/L	0.02 mg/L
ACTION LEVEL	0.015 mg/L	1.3 mg/L
METHOD	sm3113B	sm3111B/sm3113B
ANALYST	ML	ML

Lab Sample #	Date Collected	Site / Location	RESULTS Lead mg/L	RESULTS Copper mg/L	letter
05753346	08/05/15	1) Buckley - 714 Hawthorn Dr.	ND	ND	9/21/15
05753347	08/05/15	2) Casteel - 908 Patricia Ann	ND	ND	9/21/15
05753348	08/05/15	3) Teufel - 891 Margie Ann Dr.	ND	ND	9/21/15
05753349	08/05/15	4) Christian - 717 Lehman Dr.	0.0012	0.14	9/21/15
05753350	08/04/15	5) Wilson - 832 Margie Ann Dr.	ND	0.023	9/21/15

NOTES:

ND (Not Detected): In the results column, indicates this compound was analyzed and not detected at a level greater than or equal to the SRL.
 SRL (State Reporting Level): The minimum reporting level established by the Washington State Department of Health (DOH).

LAB COMMENTS: Copy sent to Washington State DOH.
