




## Water Bacteriological Analysis

**Client:** King Water Company  
PO Box 2243  
Oak Harbor, WA 98277

**Invoice Number:** 21-21317  
**PO Number:**  
**Project Name:** DW

**Report Date:** 12/22/2021  
**Approved By:** 

### Sample Information

**Date Collected:** 12/21/2021  
**Sample Purpose:** Routine Compliance  
**Sample Type:** Post Treatment/Finished Water Sample  
**Sample Composition:** Coliform Samples  
**Sample Collected by:** F. Pedroza  
**Source Number:** 00

**Date Received:** 12/21/2021  
**Suitability:** Yes  
**Chlorine Res:** 0.35  
**Repeat:**  
**Repeat Lab #:**  
**Repeat Date:**

**System Number:** 19948

**System Name:** DRIFTWOOD HEIGHTS ASSOCIATION

Lab #: 85647		Sample: 805 Patricia Ann Dr.				
Analyte	Results	Units	Detection Limit	Method	Analyst	Date Analyzed
TOTAL COLIFO -M	Satisfactory	/100ml	1	SM_9223B	AH	12/22/2021
E. COLI	Absent	/100ml	1	SM_9223B	AH	12/22/2021

**System: Driftwood Heights**

System # 19948 X

Report: December 2021

Island County

Source SO 1

Hypochlorite Solution Strength 10%

LIQUID HYPOCHLORITE 12.5%

BLANKS REPRESENT NO TEST

**LBS. OF AVAILABLE CHLORINE PER GALLON OF SOLUTION**

0.1

**QUANTITY OF WATER TREATED**

DATE	WELL #1 METER READING	VOLUME	POUNDS	Chlorine			
				Tank size	Gal. Used	Entry mg/L	Distribution mg/L
30	57,137,450			50	5	0.28	0.21
1	0	0	0	50			
2	0	0	0	50			
3	0	0	0	50			
4	57,198,100	60,650	505821	50	3	0.26	0.25
5	0	0	0	50			
6	57,230,530	32,430	270466	50	2	0.25	0.2
7	0	0	0	50			
8	0	0	0	50			
9	0	0	0	50			
10	57,292,700	62,170	518498	50	4	0.36	0.22
11	0	0	0	50			
12	0	0	0	50			
13	57,335,160	42,460	354116	50	3	0.33	0.26
14	0	0	0	50			
15	0	0	0	50			
16	0	0	0	50			
17	57,387,550	52,390	436933	50	3	0.3	0.25
18	0	0	0	50			
19	0	0	0	50			
20	57,441,620	54,070	450944	50	3	0.2	0.14
21	0	0	0	50			
22	0	0	0	50			
23	57,485,800	44,180	368461	50	3		
24	0	0	0	50			
25	0	0	0	50			
26	0	0	0	50			
27	0	0	0	50			
28	0	0	0	50			
29	0	0	0	50			
30	57,594,400	108,600	905724	50	2	0.36	0.35
31	0	0	0	50			

456,950

Total pumped for month 456,950  
 Average daily usage 15,232  
 Average per connection (111) 137

Driftwood Heights 1

Year:

Date	Mth/Day	#1 Well Meter	Average Daily Usage	Line Pressure		10th St	Hour Meters			Generator Hours	Propane Level	Sign
				Main	#1 Pump		#2 Pump	Well				
11/1/21		56,919,800	21,310	50	17,607.5	7603.7	14,871.5					
11/5/21		56,918,900	14,775	50	17,645.8	7608.4	14,884.5					
11/8/21		56,824,950	45,350	47	17,622.3	7612.5	14,888.3					
11/15/21		56,930,000	15,007	48	17,606.5	7621.4	14,896.8					
11/17/21		56,982,500	13,125	48	17,644.0	7625.5	14,901.3					
11/23/21		57,034,160	12,915	47	17,651.4	7630.5	14,905.7	304.5	40%			
11/30/21		57,137,450	14,756	47	17,655.8	7637.6	14,914.7					
12/4/21		57,198,100	15,763	47	17,674.2	7644.7	14,919.3					
12/6/21		57,230,530	16,215	48	17,678.6	7647.3	14,922.0					
12/10/21		57,292,400	15,543	48	17,689.7	7652.8	14,927.1					
12/13/21		57,335,160	14,153	48	17,693.8	7656.8	14,930.7					
12/17/21		57,387,550	13,098	49	17,702.3	7661.7	14,935.8					
12/20/21		57,441,620	18,023	48	17,708.9	7665.7	14,937.5					
12/23/21		57,485,800	14,727	48	17,714.6	7669.2	14,943.2	305.6	39%			
12/30/21		57,544,400		48	17,730.3	7678.8	14,952.2					

Notes:

11/15/21 - Power outage started Generator - Rest did not start

12/21/21 BT sample

