



Water Chemical Analysis

174 80872

Client: King Water Company
PO Box 2243
Oak Harbor, WA 98277

Invoice Number: 21-20008
PO Number:
Project Name: Gross Alpha & Radium 228

Approved By:

PWS Information

Date Collected: 11/30/2021
System Number: 19948
Lab Sample Number: 174 80872
Sample Location: Sample: Driftwood Heights So1 - Well 1
Sample Purpose: Routine Compliance
Sample Composition: Flowing Distribution Sample

Sample Collected by:

System Group Type:
System Name: DRIFTWOOD HEIGHTS ASSOCIATION
County: ISLAND
Source Number: 01
Date Received: 11/30/2021
Date Analyzed: 1/10/2022
Date Reported: 1/24/2022
Sample Type: Post Treatment/Finished Water Sample

DOH #	Analyte	Results	Units	SRL	Trigger	MCL	Method	Analyst
Radiological								
165	GROSS ALPHA*	ND	pCi/L	3.0		15	EPA_900.0	OS
166	RADIUM 228*	0.4889 +/- 0.414	pCi/L	1		5	EPA_904.0	OS

MCL = (Maximum Contaminant Level) allowed by the State of Washington.
ND = (Not Detected): Compound was analyzed and not detected at a level greater than or equal to the SRL.
SRL = (State Reporting Level) The minimum reporting level required by Washington State Department of Health (DOH).
Trigger Level = DOH drinking water response level. System with compounds detected at concentrations in excess of this level are required to take additional samples. < = (less than) indicates the analyte was below the detection limit.
OT = Out of Hold Time
*Gross Alpha & Radium 228 analysis performed by Beta Analytical (Suite 15A-02001)