



## Water Bacteriological Analysis

**Client:** King Water Company  
PO Box 2243  
Oak Harbor, WA 98277

**Invoice Number:** 23-12056

**PO Number:**

**Project Name:** DW

**Phone:** (360) 914-1395

**Report Date:** 7/14/2023

**mail:** jeremy@kingwater.com

**Approved By:** 

### Sample Information

**Date Collected:** 7/12/2023  
**Sample Purpose:** Routine Compliance  
**Sample Type:** Post Treatment/Finished Water Sample  
**Sample Composition:** Coliform Samples  
**Sample Collected by:** F. Pedroza  
**Source Number:** 00

**Date Received:** 7/13/2023

**Suitability:** Yes

**Chlorine Res:** 0.10

**System Number:** 19948

**System Name:** DRIFTWOOD HEIGHTS ASSOCIATION

Lab #: 46117		Sample: 767 Hawthorne Ln				
Analyte	Results	Units	Detection Limit	Method	Analyst	Date Analyzed
TOTAL COLIFORM	Satisfactory	/100ml	1	SM_9223B	SK	7/14/2023
E. COLI	Absent	/100ml	1	SM_9223B	SK	7/14/2023