



**Burlington, WA Corporate Laboratory (a)**  
 1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400  
**Bellingham, WA Microbiology (b)**  
 805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

**Portland, OR Microbiology/Chemistry (c)**  
 9725 SW Commerce Cr Ste A2 - Wilsonville, OR 97070 - 503.682.7802  
**Corvallis, OR Microbiology/Chemistry (d)**  
 1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946  
**Bend, OR Microbiology (e)**  
 20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425




## Washington State Department of Health WATER BACTERIOLOGICAL ANALYSIS

**Client Name:** King Water Company-NW Natural Water Sevices  
 107 S Main St  
 Coupeville, WA 98239

**Reference Number:** 24-16922  
**Project:** DRIFTWOOD HEIGHTS ASSOCIATION

**System Name:** DRIFTWOOD HEIGHTS ASSOCIATION  
**System ID Number:** 19948X  
**DOH Source Number:** 00 - Distribution Sample (Bacteria)  
**Sample Type:** D - Drinking Water  
**Sample Purpose:** C - Compliance  
**Sample Location:** 8915 Margie Ann Dr  
**County:** Island  
**Sampled By:** David Boyes  
**Sampler Phone:**

**Repeat Sample Number:**  
**Lab Number:** 164-32100  
**Field ID:**  
**Date Collected:** 6/10/24 12:00  
**Date Received:** 6/11/24  
**Date Set:** 6/11/24 12:50  
**Date Analyzed:** 6/12/24 10:10  
**Report Date:** 6/13/24  
**Comment:** Cl2: 0.39  
**Approved By:** ckk,jln

**Authorized by:**   
 Ceann K Knox  
 Lab Manager, Bellingham

DOH#	PARAMETER	RESULT	Qualifier	UNITS	Analyst	METHOD	Batch	COMMENT
1	TOTAL COLIFORM	<b>Satisfactory, Coliforms Absent</b>		per 100mL	mlp	SM9223 B	m_240611a	
3	E. COLI	<b>Absent</b>		per 100mL		SM9223 B	m_240611a	

If the sample is unsatisfactory you can get information at the following health department websites or phone numbers:

- Island Co: <http://www.islandcounty.net/health/Envh/DrinkingWater/index.htm>
- San Juan Co: <http://www.sanjuanco.com/health/ehswater.aspx>
- Skagit Co: [http://www.skagitcounty.net/drinkingwater\\_](http://www.skagitcounty.net/drinkingwater_) or 360-336-9380
- Snohomish Co: 425-339-5250
- Whatcom Co: [http://www.co.whatcom.wa.us/health/environmental/drinking\\_water/index.jsp](http://www.co.whatcom.wa.us/health/environmental/drinking_water/index.jsp)
- WSDOH: <http://www.doh.wa.gov/ehp/dw/Programs/coliform.htm>

**NOTES:**

If the result is Unsatisfactory, three (3) repeat samples and groundwater source samples are required for Group A Public Water Systems. Private individuals should investigate the cause of the unsatisfactory result and resample.  
 If E. Coli or Fecal Coliform are present in sample do not drink the water until it is properly treated.

\*If data qualifiers are present, see accompanying Qualifier Definition report.