



Burlington, WA *Corporate Laboratory (a)*
 1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400
 Bellingham, WA *Microbiology (b)*
 805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR *Microbiology/Chemistry (c)*
 9725 SW Commerce Cr Ste A2 - Wilsonville, OR 97070 - 503.682.7802
 Corvallis, OR *Microbiology/Chemistry (d)*
 1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946
 Bend, OR *Microbiology (e)*
 20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425



OR NELAP 4072
 Page 1 of 1

LEAD & COPPER RULE REPORT

Client Name: King Water Company-NW Natural Water Services
 107 S Main St
 Coupeville, WA 98239

Reference Number: 24-24998
 Project: Driftwood Heights
 Association - 19948

System ID Number: **19948**
 Lab Number: 046-48357
 Sample Purpose: C - Compliance
 Sample Composition: Single Source

System Group Type: A
 System Name: DRIFTWOOD HEIGHTS ASSOCIATION
 County: Island
 Source Number: 93 - Standing Water (Pb&Cu)
 Multiple Sources:

Approved By: anp

Authorized By:

Lawrence J Henderson, PhD
 Director of Laboratories, Vice President

Date Received: 8/20/2024
 Date Reported: 8/30/24
 Sample Type: D - Drinking Water

Lab Number	Date Collected	Site / Location	PRM #	Analyte Name	Result	Units	AL	SRL	METHOD	Lab	Analyzed	Comments
046-48357	8/19/2024	- 891 Margie Ann	9	LEAD	ND	mg/L	0.015	0.001	200.8	a	8/28/24	
			23	COPPER	0.0051	mg/L	1.3	0.005	200.8	a	8/28/24	
046-48358	8/19/2024	- 869 Margie Ann	9	LEAD	ND	mg/L	0.015	0.001	200.8	a	8/28/24	
			23	COPPER	0.0441	mg/L	1.3	0.005	200.8	a	8/28/24	
046-48359	8/19/2024	- 735 Hawthorn Ln	9	LEAD	ND	mg/L	0.015	0.001	200.8	a	8/28/24	
			23	COPPER	0.0730	mg/L	1.3	0.005	200.8	a	8/28/24	
046-48360	8/19/2024	- 862 Patricia Ann	9	LEAD	ND	mg/L	0.015	0.001	200.8	a	8/28/24	
			23	COPPER	0.0095	mg/L	1.3	0.005	200.8	a	8/28/24	
046-48361	8/18/2024	- 693 Vespar	9	LEAD	ND	mg/L	0.015	0.001	200.8	a	8/28/24	
			23	COPPER	0.0629	mg/L	1.3	0.005	200.8	a	8/28/24	
046-48362	8/19/2024	- 908 Patricia Ann	9	LEAD	ND	mg/L	0.015	0.001	200.8	a	8/28/24	
			23	COPPER	0.0294	mg/L	1.3	0.005	200.8	a	8/28/24	

NOTES:

SRL (State Reporting Level): indicates the minimum reporting level required by the Washington Department of Health (DOH).

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Specified Reporting Limit (SRL).

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.

If you have any questions concerning this report contact Lawrence J Henderson, PhD, Director of Laboratories, Vice President, at the toll-free phone number above.