



**Burlington, WA Corporate Laboratory (a)**  
 1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400  
**Bellingham, WA Microbiology (b)**  
 805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

**Portland, OR Microbiology/Chemistry (c)**  
 9725 SW Commerce Cr Ste A2 - Wilsonville, OR 97070 - 503.682.7802  
**Corvallis, OR Microbiology/Chemistry (d)**  
 1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946  
**Bend, OR Microbiology (e)**  
 20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425




## Washington State Department of Health WATER BACTERIOLOGICAL ANALYSIS

Client Name: King Water Company-NW Natural Water Sevices  
 PO BOX 2243  
 Oak Harbor, WA 98277

Reference Number: 24-37653  
 Project: Driftwood Heights Assn

System Name: DRIFTWOOD HEIGHTS ASSOCIATION  
 System ID Number: 19948X  
 DOH Source Number: 00 - Distribution Sample (Bacteria)  
 Sample Type: D - Drinking Water  
 Sample Purpose: C - Compliance  
 Sample Location: 699 Lehman Dr  
 County: Island  
 Sampled By: JL  
 Sampler Phone:

Repeat Sample Number:  
 Lab Number: 164-72526  
 Field ID: Driftwood Heights Assn  
 Date Collected: 12/17/24 11:40  
 Date Received: 12/17/24  
 Date Set: 12/17/24 18:34  
 Date Analyzed: 12/18/24 16:09  
 Report Date: 12/20/24  
 Comment: Cl2: 0.29  
 Approved By: ckk,jln

Authorized by:   
 Ceann K Knox  
 Lab Manager, Bellingham

DOH#	PARAMETER	RESULT	Qualifier	UNITS	Analyst	METHOD	Batch	COMMENT
1	TOTAL COLIFORM	<b>Satisfactory, Coliforms Absent</b>		per 100mL	mlp	SM9223 B	m_241217b	
3	E. COLI	<b>Absent</b>		per 100mL		SM9223 B	m_241217b	

If the sample is unsatisfactory you can get information on well disinfection at Washington State Department of Health:

WA DOH: <https://doh.wa.gov/community-and-environment/drinking-water/disinfection>

**NOTES:**

If the result is Unsatisfactory, three (3) repeat samples and groundwater source samples are required for Group A Public Water Systems. Private individuals should investigate the cause of the unsatisfactory result and resample.

If E. Coli or Fecal Coliform are present in sample do not drink the water until it is properly treated.

\*If data qualifiers are present, see accompanying Qualifier Definition report.