

## Washington State Department of Health WATER BACTERIOLOGICAL ANALYSIS

Client Name: King Water Company-NW Natural Water Sevices  
PO BOX 2243  
Oak Harbor, WA 98277

Reference Number: 25-11835  
Project: Driftwood Heights Assn

System Name: DRIFTWOOD HEIGHTS ASSOCIATION  
System ID Number: 19948X  
DOH Source Number: 00 - Distribution Sample (Bacteria)  
Sample Type: D - Drinking Water  
Sample Purpose: C - Compliance  
Sample Location: 848 Margie Ann  
County: Island  
Sampled By: JL  
Sampler Phone:

Repeat Sample Number:  
Lab Number: 164-24648  
Field ID: Driftwood Heights Assn  
Date Collected: 4/22/25 12:45  
Date Received: 4/22/25  
Date Set: 4/22/25 17:49  
Date Analyzed: 4/23/25 15:14  
Report Date: 4/24/25  
Comment: Cl2: 0.39  
Approved By: ckk,mlh

Authorized by:



Ceann K Knox  
Lab Manager, Bellingham

DOH#	PARAMETER	RESULT	Qualifier*	UNITS	Analyst	METHOD	Batch	COMMENT
1	TOTAL COLIFORM	<b>Satisfactory, Coliforms Absent</b>		per 100mL	mlp	SM9223 B	m_250422b	
3	E. COLI	<b>Absent</b>		per 100mL		SM9223 B	m_250422b	

If the sample is unsatisfactory you can get information on well disinfection at Washington State Department of Health:

WA DOH: <https://doh.wa.gov/community-and-environment/drinking-water/disinfection>

**NOTES:**

If the result is Unsatisfactory, three (3) repeat samples and groundwater source samples are required for Group A Public Water Systems. Private individuals should investigate the cause of the unsatisfactory result and resample.

If E. Coli or Fecal Coliform are present in sample do not drink the water until it is properly treated.

\*If data qualifiers are present, see accompanying Qualifier Definition report.