

Washington State Department of Health WATER BACTERIOLOGICAL ANALYSIS

Client Name: King Water Company-NW Natural Water Services
PO BOX 2243
Oak Harbor, WA 98277

Reference Number: 25-23731
Project: Driftwood Heights Assn

System Name: DRIFTWOOD HEIGHTS ASSOCIATION
System ID Number: 19948X
DOH Source Number: 00 - Distribution Sample (Bacteria)
Sample Type: D - Drinking Water
Sample Purpose: Investigative or Other
Sample Location: 701 Vesper Way
County: Island
Sampled By: JL
Sampler Phone:

Repeat Sample Number:
Lab Number: 164-47624
Field ID: Driftwood Heights Assn
Date Collected: 7/28/25 09:15
Date Received: 7/28/25
Date Set: 7/28/25 17:13
Date Analyzed: 7/29/25 14:49
Report Date: 8/1/25
Comment: Cl2: 0.30
Approved By: ckk,mlh

Authorized by:



Ceann K Knox
Lab Manager, Bellingham

DOH#	PARAMETER	RESULT	Qualifier*	UNITS	Analyst	METHOD	Batch	COMMENT
1	TOTAL COLIFORM	Satisfactory, Coliforms Absent		per 100mL	jln	SM9223 B	m_250728b	
3	E. COLI	Absent		per 100mL		SM9223 B	m_250728b	

If the sample is unsatisfactory you can get information on well disinfection at Washington State Department of Health:

WA DOH: <https://doh.wa.gov/community-and-environment/drinking-water/disinfection>

NOTES:

If the result is Unsatisfactory, three (3) repeat samples and groundwater source samples are required for Group A Public Water Systems. Private individuals should investigate the cause of the unsatisfactory result and resample.

If E. Coli or Fecal Coliform are present in sample do not drink the water until it is properly treated.

*If data qualifiers are present, see accompanying Qualifier Definition report.